CERTIFICATE OF COMPLIANCE

Certificate Number Report Reference Issue Date 2020-03-10-R1431 R1431-19760617 2020-MARCH-10

Issued to:

GLOBE TECHNOLOGIES CORP. 1109 W CEDAR ST. P.O. BOX 1070 STANDISH, MI 48658-1070 USA

This is to certify that representative samples of

Fusible Links See addendum page for model information

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: Additional Information: UL 33, "Heat Responsive Links for Fire Protection Service" See the UL Online Certifications Directory at for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

Barnally

Bruce Mahrenholz, Director North American Certification Program



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number Report Reference Issue Date 2020-03-10-R1431 R1431-19760617 2020-MARCH-10

| Model | Heat Responsive Type | Response Type | Temp Rating, °F | Corrosive Environment Coating/Plating Type | Design Load Inclusive, lbf | Bearing Length, in. |
|---------|----------------------------|------------------|--------------------|---|-------------------------------------|---------------------------|
| 5720* | Fusible | Standard | 155 (69°C),165 | Nickel, Zinc, Steel | 1-25, 1-5 | N/A |
| E-5720* | Fusible | Standard | 155 (69°C),165 | Nickel, Zinc, Steel | 1-25, 1-5 | N/A |

N/S - Not investigated for use in corrosive environments

N/A - Not applicable

* - During periodic inspections, the links may be activated utilizing the application of moderate heat up to and including the operation of the link and reset to restore service. Fusible links have not been evaluated for use after exposure to a fire condition.

Trademark and/or Tradename: "AMEREX", "ANSUL", "SR PRODUCTS", "PHL LINKS"

Barnally

Bruce Mahrenholz, Director North American Certification Program



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/